

# Key Largo Wastewater Treatment District Board of Commissioners Meeting Agenda Item Summary

Meeting Date:

April 16, 2024

Agenda Item Number: L-1

Action Required:

No

Department:

Plant/Facilities

Sponsor:

Ryan Dempsey

Subject:

**Plant/Facilities Report - March 2024**

Summary:

Mr. Dempsey will give the Plant/Facilities monthly report.

## Reviewed / Approved

Operations: \_\_\_\_\_

Administration: \_\_\_\_\_

Finance: \_\_\_\_\_

District Counsel: \_\_\_\_\_

District Clerk: \_\_\_\_\_

Engineering: \_\_\_\_\_

## Financial Impact

\$

Funding Source:

N/A

Budgeted:

N/A

## Attachments

1. Monthly Report

Approved By: \_\_\_\_\_

General Manager



Date: \_\_\_\_\_

4/11/2024

## Wastewater Treatment Plant Operations

The wastewater treatment plant processed an average of 2.2 million gallons of influent per day (MGD). The Treatment Plant remains in compliance with the Florida Department of Environmental Protection (FDEP) guidelines.


### Effluent Quality Reports (mg/L)

Determines the quality of discharge from the wastewater treatment plant.


Effluent Quality Report	March 2024 Plant Performance	12 Month Average Plant Performance	Effluent Limits
<b>CBOD5</b> (Carbonaceous Biochemical Oxygen Demand)	1	1.6	5
<b>TSS</b> (Total Suspended Solids)	.9	1.6	5
<b>TN</b> (Total Nitrogen)	2.7	2.6	Report only
<b>TP</b> (Total Phosphorous)	.8	.7	Report only

### Daily Flow (MGD)

The total flow of influent through the wastewater treatment plant each day.



**Daily Peak Salinity (PPT)**  
The daily peak salinity for the current month.



### Islamorada

Average Daily Flow: .810 MGD

Highest Daily Flow: 1.1 MGD

Monthly Peak Salinity: 2.8 PPT

Days over 4.0 PPT Salinity: 0

3-month average of flow capacity (1.104 MGD): 67%



## Plant WAS Line Replacement





