

Key Largo Wastewater Treatment District Board of Commissioners Meeting Agenda Item Summary

Meeting Date:
July 6, 2021

Agenda Item Number: G-1

Agenda Item Type:
Information / Presentation

Agenda Item Scope:
Review / Discussion

Recommended Action:
Discussion

Department:
Operations

Sponsor:
Ryan Dempsey

Subject:

Yeomans Sewage Pump Replacement Parts Emergency Purchase

Summary of Discussion:

Small leaks were found in the volutes of both of the 75 hp sewage pumps at Vacuum station A. This purchase was for the necessary replacement parts to permanently repair both pumps. Due to the extended delivery time of 14-16 weeks, the order needed to be placed immediately.

We installed temporary epoxy patches to both pumps to keep them in service until the permanent replacement parts arrive.

<u>Reviewed / Approved</u>	<u>Financial Impact</u>	<u>Attachments</u>
Operations: _____	\$ 33,104.00	
Administration: _____	Expense	
Finance: _____	Funding Source:	
District Counsel: _____		
District Clerk: _____	Budgeted:	
Engineering: _____	Yes	

Approved By: _____
General Manager

Date: 7-1-21

PROPOSAL

To: **Casey Garner**
Company: **Key Largo WTD**

Date: June 16, 2021

Project: **Grundfos/Yeomans Dry Pit Submersible Pump Parts Basin A**

Dear Casey:

We are pleased to offer the following replacement parts for the above referenced project:

Vacuum Station Basin A

(2) Volute Kit - Yeomans Dry Pit Submersible Pump Parts
Model 9235-4153LC

Includes:

- Volute
- Suction Cover
- Hardware
- Gaskets
- No Wear Rings Req'd

PRICE: \$33,104.00 (\$16,552.00 each)

Note: Price does **not** include installation, or any item not specifically listed in this proposal.

Terms: Net 30 days, Proposal is valid for 30 days.

Freight: Freight allowed to jobsite.

Delivery: Equipment - Approximately 14-16 weeks after receipt of order.

Thank you for the opportunity to quote on this project. Please contact us with any questions.

Sincerely,

Mark Bridges